

Certificate

Indoor Air Comfort Gold

Gypsotech joint fillers according to EN 13963

Certified Product

Fassa S.r.l.

Via Lazzaris, 3 31027, Spresiano (TV) Italy

Applicant

The above product complies with the Indoor Air Comfort Gold specifications, version 9.0 (2023). These include both inspection of factory production and VOC emissions testing according to EN 16516, at regular intervals. Indoor Air Comfort Gold combines all key European and selected global requirements on VOC product emissions. Additional requirements not related to VOC product emissions, for example content of certain substances or odour are not combined or evaluated. The following VOC emission requirements are combined and the certified product shows compliance with these VOC emission related limit values:

- France VOC class A+
- Germany (AgBB/ABG)
- Italian CAM Edilizia
- EU Taxonomy Regulation
- LEED (ACP)
- BREEAM New Construction
- WELL Building
- SKA Rating
- French HQE certification
- EMICODE EC1 Plus
- Blue Angel DE-UZ 198
- Danish Indoor Climate Label (Emission Class 1)
- BVB (Sweden)
- Miljöbyggnad (Sweden)
- Eco Product Norway
- SINTEF (Norway)
- Cradle to Cradle
- very low emitting products according to EN 16798-1
- Singapore Green Label
- Declare 2.0

Issue date: 12 June 2025

Validity date: 12 June 2030

This certificate is valid as specified if regular surveillance and testing is done.

Product type: Wall Fillers

Certificate number: IACG-453-01-03-2025

Thomas Neuhaus

Head of Certification Body

Eurofins Product Testing A/S Smedeskovvej 38, Gate 9 8464 Galten Denmark





Appendix to Certificate IACG-453-01-03-2025

Fassa S.r.I.

receives the Indoor Air Comfort Gold certificate with validity 12 June 2030

for below product group, including subgroups and individual products as listed:

Product group: Gypsotech joint fillers according to EN 13963

Product type: Wall Fillers

Products included:

BIGJOINT
FASSAFLASH
FASSAJOINT 1H
FASSAJOINT 2H
FASSAJOINT 3H
FASSAJOINT EXTRA
FASSAJOINT IDEAL 3.5

The products in this group are based on identical or similar recipe and are produced under equivalent conditions. Grouping of the products and inspection of the production process is part of the Indoor Air Comfort Gold certification. A worst-case product, which is representative for the whole group, is being tested frequently.

